

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 1080-0035:111 Page 1 of 1

CATEGORY: Walls/Partitions

LISTING: O'Keeffe's Inc., *325 Newhall Street, San Francisco, CA 94124-1432
Contact: Kevin Turner (415) 822-4222 FAX (415) 822-5222

DESIGN: Model "SUPERLITE II XL" Transparent Composite Panels in wall frame. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 60 minutes
Nominal 1" in thickness

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and Warnock Hersey label.

APPROVAL: Listed as 60-minute fire-rated glazing material for use in non-bearing fire rated wall framing system in 1-Hour locations.

Opening dimensions		
Max. Allowable Clear View Area	4952 in ²	2050 in ²
Max. Allowable Clear View Width	106.5"	124.25"
Max. Allowable Clear View Height	106.5"	124.25"
Minimum Stop Depth	5/8"	5/8"

NOTE: Allowances:
1. Patterns, Opaque, Tints
2. Exterior glazing composed of an additional laminate glazing layer with PVB acceptable, including an additional glazing panel.

*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager